

Engineering Conditions of Acceptability:

For use only in or with complete equipment where the acceptability of the combination is determined by UL LLC. When installed in an end-product, consideration must be given to the following:

- The following Production-Line tests are conducted for this product:
Electric Strength, Earthing Continuity
- The following secondary output circuits are SELV: All
- The following secondary output circuits are at hazardous energy levels:
All
- The power supply terminals and/or connectors are: Suitable for field wiring
- The maximum investigated branch circuit rating is: 20 A
- The investigated Pollution Degree is: 2
- Proper bonding to the end-product main protective earthing termination is: Required
- An investigation of the protective bonding terminals has: Been conducted
- The following input terminals/connectors must be connected to the end-product supply neutral: Middle terminal marked "N".
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): PFC board: L1 (Class B), Main board: L1, L2, L3, L4, (Class B)
- The following end-product enclosures are required: Mechanical, Fire, Electrical
- The equipment is suitable for direct connection to: AC mains supply