

Engineering Conditions of Acceptability:

For use only in or with complete equipment where the acceptability of the combination is determined by UL LLC. When installed in an end-product, consideration must be given to the following:

- The following Production-Line tests are conducted for this product:
Electric Strength
- The following secondary output circuits are SELV: All
- The power supply terminals and/or connectors are: Suitable for field wiring
- The maximum investigated branch circuit rating is: 20 A
- The investigated Pollution Degree is: 2
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): L3 - Class 130 (B) (see appended table 1.5.1)
- The following end-product enclosures are required: Fire , Electrical
- The following secondary output circuits are at non-hazardous energy levels: All
- The end-product Electric Strength Test is to be based upon a maximum working voltage of: Primary-SELV: 256 Vrms, 614 Vpk