

CONDITIONS OF ACCEPTABILITY:

1. THESE DEVICES SHALL BE USED WITHIN THEIR RECOGNIZED RATINGS AS DESCRIBED IN THE RATINGS SECTION ABOVE.
2. THE SUITABILITY OF THE MOUNTING MEANS IS TO BE DETERMINED IN THE END USE APPLICATION.
3. THESE DEVICES HAVE BEEN EVALUATED FOR FACTORY WIRING ONLY.
4. IN THE END APPLICATION FREE AIR SPACE SHALL BE PROVIDED IN FRONT OF THE CAPACITOR TERMINALS TO ENABLE THE CAPACITOR TO EXPAND, WITHOUT OBSTRUCTION, UNDER A FAULT CONDITION. THIS EXPANSION CLEARANCE SPACE SHALL BE SUFFICIENT TO ALLOW THE FRONT COVER AND TERMINALS OF THE CAPACITOR, WITH ASSOCIATED WIRE CONNECTIONS AND SUPPLY LEADS ATTACHED, TO TRAVEL 12.7 MM (1/2 IN.) IN A DIRECTION PERPENDICULAR TO THE COVER (MOUNTING SURFACE OF THE TERMINALS) .
5. THESE DEVICES HAVE BEEN EVALUATED FOR USE WITH A MINIMUM 75°C CONDUCTORS.